


LOUVER SCHEDULE											
WINDOW	LOUVER		MAT'L	TYPE SEE ELEV	FINISH	FRAME		FIRE LABEL	DESIGN PRESSURES		REMARKS
	W	H				MAT'L	FINISH		+	-	
1	4'-0"	4'-0"	IMPACT RESISTANT ALUMINUM	AA	KYNAR	ALUM	KYNAR	-	+52.00	-56.00	WIND DRIVEN RAIN LOUVER
2	2'-0"	2'-0"	IMPACT RESISTANT ALUMINUM	BB	KYNAR	ALUM	KYNAR	-	+52.00	-56.00	WIND DRIVEN RAIN LOUVER
3	1'-6"	1'-0"	IMPACT RESISTANT ALUMINUM	CC	KYNAR	ALUM	KYNAR	-	+52.00	-56.00	WIND DRIVEN RAIN LOUVER



*LARGE MISSILE IMPACT RESISTANT EXTERIOR ALUMINUM LOUVER BY CONSTRUCTION SPECIALTIES MODEL DCH-5704. PROVIDE (3) COATS OF KYNAR FINISH ON ALL LOUVERS, OR APPROVED EQUAL. PROVIDE 20 YEAR MANUFACTURER'S WARRANTY MIN. ON ALL LOUVER COMPONENTS AND FINISH.

NOTES:

1. WIND-LOAD DESIGN PRESSURE CALCULATIONS SHALL BE FOR 200 MPH WIND SPEEDS
2. LOUVERS SHALL BE TESTED TO LEVEL E MISSILE IMPACT AT A SPEED OF 80 FEET PER SECOND.
3. SUBMIT PRODUCT APPROVAL COMPLY w/ FBC SIXTH EDITION (2017) AND ASCE 7-10
4. FIELD VERIFY ALL EXISTING DIMENSIONS PRIOR TO BIDDING THE PROJECT AND ORDERING ANY MATERIALS. DIMENSIONS SHOWN HERE ARE APPROXIMATE AND SHOULD BE USED ONLY AS REFERENCE TO AID IN THE BID PROCESS. CONTRACTOR IS RESPONSIBLE FOR FIELD VERIFYING SIZE OF ALL EXISTING OPENINGS AND COORDINATING INSTALLATION BETWEEN MANUFACTURING FACILITIES AND CONSTRUCTION PERSONNEL. TYPICAL




CONTRACTOR SHALL USE NON-CORROSIVE STAINLESS STEEL 316 FASTENERS FOR ALL APPLICATIONS. TYPICAL



LOUVER SCHEDULE / ELEVATIONS

SCALE: 3/8" = 1'-0"



1 WIND DRIVEN RAIN LOUVER DETAIL

SCALE: NTS

WALTERS ZACKRIA ARCHITECTS
 5813 N. ANDREWS WAY
 FORT LAUDERDALE, FL 33309
 PHONE: (954) 522-4123
 FAX: (954) 522-4128
 www.wza-architects.com
 Abbas H. Zackria, FL AR 91520
 Florida Registration: AA2600970
CORPORATE NAME: WALTERS ZACKRIA ASSOCIATES, PLLC REGISTERED IN THE STATE OF FLORIDA. WRITTEN DIMENSIONS TAKE PRECEDENCE OVER SCALED DIMENSIONS. THESE DRAWINGS ARE THE PROPERTY OF WALTERS ZACKRIA ASSOCIATES, PLLC, AND SHALL NOT BE REPRODUCED WITHOUT WRITTEN PERMISSION FROM A PRINCIPAL OF THE FIRM OR BE LIABLE FOR THE FULLEST LEGAL RECOURSE. CONTRACTOR SHALL VERIFY ALL EXISTING CONDITIONS AND DIMENSIONS AND NOTIFY THE ARCHITECT OF ANY DISCREPANCIES PRIOR TO EXECUTION OF WORK.

**CITY OF NORTH LAUDERDALE
 FIRE STATION 44 RENOVATION
 WIND MITIGATION PROJECT
 7700 HAMPTON BLVD.
 NORTH LAUDERDALE, FL 33068**

DRAWN BY: OM/AC
 CHECKED BY: AZ
 DATE: 03/12/20
 REVISIONS:

- △
- △
- △
- △
- △