



## **ADDENDUM #1 TO CONTRACT DOCUMENTS**

### **REQUEST FOR PROPOSALS (ITB) # 20-01-389** **PORTABLE GENERATORS FOR LIFT STATIONS**

**\*\*This Addendum MUST be acknowledged via the “Addendum Acknowledgement Form” in ITB\*\***

**Addendum Date:** January 24, 2020

#### **TO ALL PROSPECTIVE RESPONDERS:**

Responders, for the above referenced project shall take note of the following revisions, additions, deletions, clarifications, etc. relative to the solicitation, which in accordance with the Contract Documents shall become a part of and have precedence over anything shown or described otherwise.

<b>Big Air Mechanical</b>	
<b>QUESTION(S)</b>	<b>RESPONSE(S)</b>
I have my Mechanical Class “A” Contractors License for the state of Florida and the way I read your qualifications that would qualify us for this bid. Could you please confirm. Thanks for your time in advance.	You must provide proof of any current Florida contractor’s license. Mechanical Class “A” would be acceptable to satisfy this requirement.
<b>Trekker Group</b>	
<b>QUESTION(S)</b>	<b>RESPONSE(S)</b>
First, thank you for the opportunity the City of North Lauderdale is giving Trekker Tractor LLC to be a part of this Bid. Refer to the attached presentation of the Parallel Control; I would like the opportunity to talk to the end user to better explain this feature, I know that the requested units will be used for lifting stations, but with this feature can give a great turn to its use, you can have a better use for emergencies. I am in you to be able to present this option, this Friday I am open to meet if you wish. Thanks again.	The Parallel Control feature is not needed for this application. The Cone of Silence prohibits you from communicating with any members of the Evaluation Committee Members or end-user(s) regarding this ITB. Failure to do so could result in your bid being disqualified. Please email any and all questions regarding this ITB to <a href="mailto:dkcancel@nlauderdale.org">dkcancel@nlauderdale.org</a> for clarification or information concerning the subject solicitation.



---

<b>Zabatt Power Supply</b>	
<b>QUESTION(S)</b>	<b>RESPONSE(S)</b>
<p>I am not clear on what I need to do to receive your approval to submit an alternative manufacturer. It looks like I need to do something 5 days prior to provide an alternative for approval package. Can you clarify?</p>	<p>The end-user(s) will decide if your alternative is compliant to the department's needs. Please prepare your bid and all related information for submission.</p> <p>(5) days prior to the date fixed for opening bids, prospective bidders must request from the Purchasing Coordinator interpretation of the meaning of plans, specifications or other contract documents in writing.</p>
<b>On-Site Power Inc.</b>	
<b>QUESTION(S)</b>	<b>RESPONSE(S)</b>
<p>We would like to submit Gillette generators for approval as an equal on this project. Gillette is an American owned company that has been in business since the early 1960's. They manufacture to industry standards such as UL200, UL142, etc. which will insure equality. I thank you in advance for your consideration.</p>	<p>The end-user(s) will decide if your alternative is compliant to the department's needs. Please prepare your bid and all related information for submission.</p>



---

In addition to the above questions and answers, the following modifications to the documents are made:

For clarification, the term “approved” is applicable to the awarded bidder. Any equivalents you would like to submit for consideration will be accepted and does not require pre-approval by the Purchasing Coordinator prior to submission.

**Page 8 – Section 6 is applicable to the above clarification:**

**ITB Specification:**

**DCA125SSIU4F WhisperWatt™ Diesel Generator or approved equal**

**Page 9 – Section 6, RATINGS is applicable to the above clarification:**

The sound attenuated generator set shall be MQ Power model DCA125SSIU4F or **approved equal**, rated for continuous, Prime Power operation at 100kW [125kVA], with a Standby Rating of 110kW [137.5kVA] 0.8 P.F., 3-phase, 4-wire, 60 Hz.

**Page 24 – Section 10.A is applicable to the above clarification:**

Identify the specific product the contractor is able to provide at the bid price. Include any and all brochures and explicit manufacturer specifications on the approved equivalent.

All other documents, specifications, drawings, terms and conditions remain the same.

END OF DOCUMENT