



ADDENDUM #3 TO CONTRACT DOCUMENTS

REQUEST FOR PROPOSALS (RFP) # 19-11-386 **FIRE STATIONS 34 & 44 WIND RETROFIT-HMGP**

****This Addendum MUST be acknowledged via the “Addendum Acknowledgement Form” in RFP****

Addendum Date: JANUARY 21, 2020

TO ALL PROSPECTIVE RESPONDERS:

Responders, for the above referenced project shall take note of the following revisions, additions, deletions, clarifications, etc. relative to the solicitation, which in accordance with the Contract Documents shall become a part of and have precedence over anything shown or described otherwise.

Mandatory Pre-Proposal Meeting	
QUESTION(S)	RESPONSE(S)
Shall the work provide protection against 200 MPH winds or 170 MPH as indicated?	The building and all its exterior components shall provide protection against 180 MPH winds as per Section 1620.2 Broward County, Risk Category IV Buildings, of the FBC Sixth Edition (2017). In addition, the Large Missile Impact Tests shall comply with 1626.2.4 80 feet per second impact for Risk Category IV Essential Facility buildings.
What is the powder-coated color for the garage door?	The color scheme will be as follows from Sherwin Williams: For the Main Fire Station Building: SW 6321 Red Bay for the Bay Garage Doors SW 7005 Pure White for the Roof Trim, Entry Doors, Utility Doors, Pink/Red Stripe around Building, Blue-colored Indentation SW 6122 Camelback for the Main Color of the Building For the Generator Building: SW 7005 Pure White for the Roof Trim, Blue-colored Indentation, and Pink Stripe around Building SW 6321 Red Bay for Main Entry Door SW 6122 Camelback for the Main Color of the Building



All other documents, specifications, drawings, terms and conditions remain the same.

END OF DOCUMENT